



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD
DISTRICT WATER TESTING LABORATORY

No-25,Perumal Vadakku Theru, Madapuram Thiruvarur-610001.

Phone:04366-221300

E-mail:dwtlthiruvarur@gmail.com

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Test Report No: 25058	Report Issue Date :	15.04.2023
Invoice Details: 03414		

Client Name & Address Contact No / Email.ID	: Maharishi vidhya Mandir,Sec.School, 263/1A-9,Mahatma Gandhi Nagar, Senthamangalam, Thiruvarur.
Sample Name	: Borewell Water
Sample Description	: Drinking Water
Sample Submitted by	: Customer
Location & Date	: School campus, & 06.04.2023
Quantity of sample Received	: 2L
Sample Container	: Jerry Cane.
Sample Condition on Receipt	: Good
Sample Received On	: 06.04.2023
Test Commenced on	: 06.04.2023
Test Completed on	: 15.04.2023
Environmental Condition	: 24.2° C

S.No	Parameters	Test Method	.Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit
1	pH	IS 3025 part 11-1983	--	7.86	6.5-8.5	6.5-8.5
2	Total Alkalinity	IS 3025 part 23-1986	mg/L	260	200	600
3	Total Hardness as CaCO3	IS 3025 part 21-2009	mg/L	120	200	600
4	Nitrate as NO3	APHA 23 rd Edition 2017-4500-NO3 B	mg/L	19	45	45
5	Chloride as Cl	IS 3025 part 32-1988	mg/L	120	250	1000
6	Fluoride	APHA 23 rd Edition 2017-4500-F-D	mg/L	0.2	1.0	1.5
7	Sulphate	IS 3025 part 24-1986	mg/L	138	200	400

Authorised Signatory

Er.R.Ramasamy M.E - Assistant Executive Engineer

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The Result applied to the sample as Received basis